# KJ3223X1-BA1 AI 16 CH 4-20mA HART CARD SERIES 2

Hazardous Atmosphere



II 3 G Ex nA [ic] IIC Gc II 3 G Ex nA [nL] IIC Gc FM13ATEX0034U IECEx FMG 13.0015U

### **Power Specifications**

Local Bus Power Bussed Field Power Field Circuit

12 VDC at 150 mA 12 VDC at 600 mA 24 VDC at 32 mA/Ch.

## **Environmental Specifications**

Ambient Temperature	-40 °C to +70 °C
Shock	10 g half-sine wave for 11 ms
Vibration	1 mm peak to peak from 2 to 13.2 Hz; 0.7 g from 13.2 to 150 Hz
Airborne Contaminants	ISA-S71.04 –1985 Airborne Contaminants Class G3
Relative Humidity	5 to 95% Non-Condensing
Terminal block key position	A2

**Note:** Refer to the product label for serial number and location and date of manufacture.

**Warning**: This product has specific instructions for installation, removal and operation in hazardous areas. Refer to document 12P2046 "DeltaV<sup>TM</sup> Scalable Process System Zone 2 Installation Instructions". Other installation instructions are available in the "DeltaV<sup>TM</sup> S-series and CHARMs Hardware Installation" manual.

### **Removal and Insertion**

Field power supplied to this device, either at the field terminal or as bussed field power through the Carrier, must be removed before removing or connecting the device.

An I/O loop assessment must be complete on all energy limited nodes.

This unit cannot be removed or inserted with system power energized.

A rotary keying system ensures compatibility between I/O cards and terminal blocks after installation is complete. The terminal block must have the keys set for the I/O card with which it is to be used.

### Maintenance and Adjustment

This unit contains no user serviceable parts and should not be disassembled for any reason. Calibration is not required.

### Other Safety Approvals





